


# Retro-Fit Gas Logs

## Gas Pipe Tests

Retro-fit gas logs/fireplaces will need a gas pipe test whether installed by a person licensed by the State of Colorado or Larimer County.

Please be aware of the following prior to testing:



1. Gas pipe tests may be performed and verified by a person licensed for gas piping in lieu of an inspection by a Larimer County Building Inspector. **This applies to gas log installation only.**

If a person licensed for gas piping does not fill out the attached form, then an inspection will need to be completed by Larimer County.

2. The test shall be at 10# air pressure for a minimum duration of 10 minutes.
3. After installation is complete with logs in place and operable, call 498-7697 or visit **onlineportal.larimer.org** to schedule a final inspection by Larimer County.
4. The attached form letter must be filled out and left with the inspection card at the job site.

**PERMIT #** \_\_\_\_\_

I verify that the gas pipe installed at

(address) \_\_\_\_\_

Maintained 10# pressure for a duration of 10 minutes with no detectable drop in pressure.

With my signature I verify that the pressure test exceeds 2021 International Residential Code or the 2021 International Fuel Gas Code requirements, and I release Larimer County from any liability.

State of Colorado Master Plumber or County Mechanical or Gas Pipe

License Number: \_\_\_\_\_

Company Name: \_\_\_\_\_

Signed: \_\_\_\_\_

Date: \_\_\_\_\_