

Technical Revisions to the LCUASS (2023)

Standard	Page	Item	Description/How Changed
Section 22.5.7	22-47	Placement Temperatures Typo	Fixed Typo. Temperature references Table 22-9.
Appendix E	Note #6	Standard Erosion and Sediment Control Construction Plan Notes (Loveland)	Changed note #6. Period a site can be left disturbed from 30 days to 14 days per CDPHE requirements.
Appendix E-1-FC/Lar	General Note #17	Certification of Grading & Drainage Facilities	Changed General Note #17 to: Certification of grading and drainage facilities must be completed by a registered engineer and submitted to the Stormwater Utility Department at least two weeks prior to Stormwater Utility Department acceptance, or otherwise in accordance with the Development Agreement.